

+91 9324 454 323

+91 9321 478 429



OM SAI FIRE PROTECTION

Maharashtra Govt. License Contractor

License No. MFS-LA/RF-287/MFS-LA/RD-278/MFS-LA/RP-055

OSFP/LIC-B/550/25-26

FORM 'B'

Section 3 (3) and Rule 4 (2)

Six Monthly Certificates to be given in e every January and July by the Owner or the Occupier for Compliance of the Fire Prevention and Life Safety Measures

CERTIFICATE

Certified that We have carried out inspection of the Fire Prevention and life safety measures installed in the following Building or Premises namely :

**M/S. Shree Rishikesh Shikshan Prasarak Mandal,
(Bapusaheb D. D. Vispute Primery English School)**

Gut No. 103 & 104, at Devad Vichumbe, Tal. Panvel, Dist. Raigad.

We further certify that these installations in the above mentioned building are maintained in good repair and efficient conditions during the period from July 2025 to December 2025 as required under the Provision of the Maharashtra Fire Prevention and Life Safety Measures Act 2006 (Mah. III of 2007). The details of the inspection of installations carried by us are mentioned in the report appended herewith.

Place : Navi Mumbai

Signature and Address of the Licensed Agency

Date : 09/02/2026

License No. MFS – LA/RF -287

License No. MFS – LA/RD -278

License No. MFS – LA/RP - 055

+91 9324 454 323

+91 9321 478 429



OM SAI FIRE PROTECTION

Maharashtra Govt. License Contractor

License No. MFS-LA/RF-287/MFS-LA/RD-278/MFS-LA/RP-055

OSFP/LIC-B/550/25-26

Annexure to Form 'B'

**M/S. Shree Rishikesh Shikshan Prasarak Mandal,
(Bapusaheb D. D. Vispute Primery English School)**

Gut No. 103 & 104, at Devad Vichumbe, Tal. Panvel, Dist. Raigad.

Sub.:- Installation Report of Fire Equipments installed at above site,

S. No.	Description	Qty.
1	Down Comer 100 mm dia	02 Nos.
2	Hydrant Valves (Single)	08 Nos.
3	Hydrant Valves (Courtyard)	04 Nos.
4	Hose Rill Drums with Rubber Pipes/Nozzles on each Floors	08 Nos.
5	Hose Boxes	12 Nos.
6	C P Hose with M/F Couplings on alternate Floors.	12 Nos.
7	Short Branch Pipes with Nozzles.	12 Nos.
8	Booster Pumps – 5 HP	01 No.
9	ABC Type Fire Extinguishers 6 Kg. Capacity	22 Nos.
10	CO2 Type Fire Extinguishers 4.5 Kg. Capacity	01 No.
11	Seamese Connection	01 No.
12	Over Head Water Tank For Fire Fighting	01 No.

Place: Navi Mumbai

Date : 09/02/2026

Yours Faithfully
For Om Sai Fire Protection

Partner



OM SAI FIRE PROTECTION

Maharashtra Govt. License Contractor

License No. MFS-LA/RF-287/MFS-LA/RD-278/MFS-LA/RP-055



**Govt. of Maharashtra
Directorate of Maharashtra Fire & Emergency Services**

Vidyanagri, Hans Bhugra Marg, Santacruz (East),
Mumbai – 400 098, Tel-022-69820595, Fax-022-26677666
www.mahafireservice.gov.in

FORM N

[(See section 9 (3) and rule 14)

**License to act as a License Agency for the purpose of
Fire Prevention and Life Safety Measure**

License No. MFS / LA / RF-287 / RD-278 / RP-55

Date: 05.12.2025

License is hereby renewed under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measure Act, 2006 (Mah. III of 2007) to **M/s. Om Sai Fire Protection** having their registration office at **Shop No. 01, Today Callisto, Plot No. 260, Sector 17, Ulve Node, Navi Mumbai 410206** and their contact details are Office Number: 9324454323 and Email ID: omsaifireprotection101@gmail.com with PAN registration No. AADFO8226B and GST No. 27AADFO8226B1ZH to act as a License Agency for the purpose of the said Act for execution of the fire prevention and life safety measures in relation to

- | | |
|---|---------|
| 1. Fire Fighting and Sprinkler System: | Class A |
| 2. Detection and Fire Suppression System: | Class C |
| 3. Passive System: | Class C |

M/s. Om Sai Fire Protection shall not issue Form A or Form B under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance failing which license granted / renewed shall be suspended or cancelled as per sub section (4) of section 9 and shall be liable for penalty under section 36 of the Act.

Subject to the provision of sub section (4) of section 9 of the said Act and rule 14 of the Maharashtra Fire Prevention and Life Safety Measures Rules, 2009, the license will be valid for a period from **05.12.2025 to 04.12.2027**

License Agency Digital Sign

VINAYAK

TANAJI

SHINDE

Note:

* in absence of digital sign of license holder (responsible to issue Form A or Form B) the license will be treated as invalid.

Digitally signed by
VINAYAK TANAJI
SHINDE
Date: 2025.12.06
10:15:04 +05'30'

SANTOSH
SHRIDHAR
WARICK

(S S Warick)

Director
MF&ES, Mumbai

Digitally signed by
SANTOSH SHRIDHAR
WARICK
Date: 2025.12.07 21:42:27
+05'30'